

Village of Northfield Building Department

H. JASON WALTERS, BUILDING & ZONING SUPERINTENDENT
199 LEDGE RD
Northfield, OH 44067

Phone: 330-467-7139, Ext. 20

NOT APPROVED

Fax: 330-908-7014

To Sellers and Purchasers of Real Estate in the Village of Northfield:

Please be advised that the Village of Northfield's Point of Sale Exterior Inspection Ordinance is designed to assist with maintaining the quality of the Village's housing stock and real estate values. In performing such point of sale exterior inspections and issuing certificates of exterior inspection, the Village does not insure, warrant, or guarantee that the inspection certificate contains all of the violations of the Village's Codified Ordinances or defects concerning the property. Such inspections should be considered by all parties as the Village's best effort to make known to owners and purchasers of real estate the known exterior maintenance violations on a given property at the time the exterior inspection is made.

Likewise, in issuing a compliance document pursuant to the point of sale inspection ordinance, the Village does not insure, warrant, or guarantee the quality of repairs or standard of work exhibited in the correction of violations listed on the inspection certificate. Such document should be construed only as a statement by the Village that some or all of the violations listed on the inspection certificate have been corrected to the Village's satisfaction.

The Village's exterior point of sale inspection should not in any way be considered as a substitute for a private home inspection.

Very truly yours,
H. Jason Walters, Building and Zoning Inspector,
Village of Northfield

POINT OF SALE/PROPERTY MAINTENANCE VIOLATION INSPECTION

Requested by: CUTLER REAL ESTATE-STEVE BURGESS
Address Inspected: 206 MAY AVE., NORTHFIELD OH 44067
Property Owner: BANK OWNED
Phone: 330 656 1081; JLAWLER@CUTLERHOMES.COM

Date Inspected: 8/5/14

Certificate Approval Date:

VIOLATIONS WILL BE BOLDED, UNDERLINED ALONG WITH A DESCRIPTION OF VIOLATION IN EACH SECTION.

DESCRIPTION

WORK ORDER

1. EXTERIOR ELECTRICAL: 1422.05 Commercial; 1490.02 Residential

A. Fixtures improperly installed	Correct or remove
B. Outlets improperly installed	Correct or remove
C. Improper overhead clearance	Adjust proper clearance
D. Devices not weatherproof	Replace or remove
E. Yard or area lights	Remove or install per code
<u>F. Light fixtures</u>	<u>Replace protective globe/fixture</u>
G. Code violation	Update/repair/replace
H. Door Bell	Repair/replace
I. Main service line	Replace/Summit County Permit

2. SIDEWALLS: 1422.04 Commercial; 1422.07 Commercial; 1490.05 Residential

A. Deteriorated sill plates	Replace sill plates
B. Buried/missing sill plates	Replace sill plates
C. Deteriorated missing studs	Replace studs
D. Deteriorated missing siding	Replace siding
E. Out of plumb vertically	Replace vertically
F. Out of horizontal alignment	Realign horizontally
G. Unprotected exterior surface	Replace/prime/coat all wood
H. Deteriorated brick or stone	Replace/repair
I. Mortar joints not weather tight	Rake and properly repoint
J. Deteriorated fascia/trim	Replace
K. Deteriorated sash/trim/sill	Replace

NO VIOLATIONS

3. ROOF/ROOFING MATERIAL: 1422.04 Commercial; 1422.05 Commercial; 1490.04 Residential; 1490.05 Residential

A. Multiple layers of shingles	Remove/replace
B. Deteriorated/sagging structural frame	Replace/repair
C. Deteriorated sheathing	Replace/repair
D. Deteriorated missing covering	Replace/repair
<i>E. Down spouts/gutters missing</i>	<i>Replace/repair</i>
F. Gutters improperly connected	Install as required
<i>G. Down spouts not connected</i>	<i>Properly connect to sewer</i>
H. Broken/deteriorated shingles/slates	Replace to match

I. Loose shingles/slates	Fasten properly
J. Missing shingles/slates	Replace to match
K. Loose or missing flashing	Fasten or replace
<u>L. Shingle life expired</u>	<u>Replace</u>
M. Roofing/structure is questionable	Contractor Inspection needed

REMOVE OLD ROOFING & REPLACE.

4. DOORS: 1422.05 Commercial; 1490.05 Residential; 1422.02 Commercial; 1490.02 Residential

<u>A. Deteriorated or missing door to pool area</u>	<u>Replace or install doors</u>
B. Broken missing glass	Replace/repair
C. Improperly installed hardware	Replace/repair
D. Non-functioning hardware	Replace/repair
E. Damaged overhead/service doors	Replace/repair
F. Damaged or missing storm door	Install or repair
G. Patio Door – Damaged/deteriorated	Replace/repair

REAR MAN DOOR/FRONT STORM DOOR BROKEN HANDLE.

5. WINDOWS: 1422.05 Commercial; 1490.05 Residential

A. Frames loose unsound	Replace/repair
B. Sash broken/loose/unsound	Replace/repair
C. Glass broken missing	Replace
D. Loose missing glazing	Replace
E. Deteriorated frame or sash	Replace
F. Improper/unfinished installation	Finish/repair

NO VIOLATIONS

6. YARD AREA/SHRUBBERY: 660.17, 660.14(e), 660.17, 660.18; 1024.04 Commercial/Residential

A. Grass Over 8” high	Mow and Maintain
B. Noxious Weeds	Remove and prevent recurrence
<u>C. Dead/diseased trees</u>	<u>Remove</u>
D. Debris and litter	Remove
<u>E. Overgrown and untrimmed</u>	<u>Trim and maintain</u>
F. Overgrown in the right of way	Trim and maintain
<u>G. Landscaping</u>	<u>Trim and maintain</u>

REMOVE DEAD PINE TREE IN FRONT – TRIM AND/OR REMOVE SHRUBS, TREES FRONT PROPERTY LINE AND SIDE PROPERTY LINE.

7. DRIVEWAY/PRIVATE & PUBLIC WALKS/APRONS/PATIOS:

1422.05 Commercial; 1490.05 Residential; 1422.075 Commercial; 1490.075 Residential

A. Concrete spalled 50% or more	Replace or repair
B. Concrete cracks over 1"	Repair
<u>C. Trip hazards exceeding 1"</u>	<u>Repair</u>
D. Too severe slope	Repair or replace
E. Obstruction inside walk area	Remove
<u>F. Loose, rocking/un-level/missing walk</u>	<u>Repair or replace</u>
G. Too smooth surface/slippery	Repair or replace
<u>H. Deteriorated asphalt/concrete</u>	<u>Repair cracks/depressions</u>
I. Paver stones unlevelled	Level or remove/replace
J. Apron poor condition	Remove and replace
K. Driveway 50% or more in need of repair	Remove and replace
L. Section(s) of concrete with severe cracks	Remove and replace
M. Concrete/asphalt with gaps exceeding 1/4"	Repair/fill
<u>N. Asphalt crack/fill & seal maintenance</u>	<u>Crack fill & seal</u>
O. Stone Driveway -Ord#1278.01	Replace with concrete/asphalt

REMOVE/REPLACE FRONT WALK – ASPHALT DRIVE HAS AREAS THAT NEED REMOVED-REPLACE/MAINTENANCE THE REST OF THE DRIVE.

8. FENCING:

1422.05 Commercial; 1490.05 Residential; 1422.075(1) Commercial; 1490.075(1) Residential

A. Inadequate structural frame	Replace/remove fence
B. Deteriorated and/or broken members	Replace/remove fence
C. Zoning code compliance	Remove/seek variance
D. Gates and hardware non-functional	Remove/repair/replace
E. Chain link fence	Paint/repair/replace

NO VIOLATIONS

9. IDENTIFICATION HOUSE NUMBERS: 1474.01 (house/building); 1475.01 (mailbox)

A. Number missing	Install required numbers
B. Number incomplete	Install missing numbers
C. Not legible	Make readable from street
D. Mailbox	Repair/replace

NUMBER IS ON THE GARAGE.

10. PAINTED SURFACES: 1422.05 Commercial; 1490.05 Residential

<u>A. Alligatored finish</u>	<u>Prepare/prime/re coat</u>
<u>B. Severely blistered</u>	<u>Prepare/prime/re coat</u>
<u>C. Cracked or peeling</u>	<u>Prepare/prime/re coat</u>
D. Bare Wood	Prep/paint

HOME & TRIM NEEDS PREP & PAINTED.

11. **SIDING AND TRIM:**

1422.05 Commercial; 1490.04 Residential; 1422.05 Commercial; 1490.05 Residential

A. Broken/bent/dented/cracked siding	Replace or repair
B. Deteriorated or rotted siding	Replace or repair
C. Broken/dented trim (corner boards)	Replace or repair
D. Deteriorated easing, jambs, sill	Replace or repair
E. Deteriorated/damaged shutter	Replace or repair
F. Deteriorated/damaged/missing fascia/soffit	Replace or repair
<u>G. Siding soiled</u>	<u>Needs washed</u>
H. Aluminum Siding	Faded/oxidized-wash/paint

WOOD SIDING NEEDS RESTORED

12. **GUTTER/DOWN SPOUTS AND SANITARY MAIN:**

1422.04 Commercial; 1490.04 Residential

<u>A. Improper connections/Storm sewer</u>	<u>Properly install at storm sewer</u>
<u>B. Damaged down spouts/gutters</u>	<u>Replace or repair</u>
<u>C. Deteriorated down spouts</u>	<u>Replace or repair</u>
<u>D. Deteriorated gutters</u>	<u>Replace or repair</u>
<u>E. Loose or open</u>	<u>Repair</u>
F. Cross connection recorded	Contact service department
<u>G. Gutters full of debris</u>	<u>Need cleaned</u>
*H. Evidence of sanitary sewer issues	Camera inspection required-needs to be recorded-on DVD only
<u>I. All clay tile sanitary main lines from home to curb – must be filmed</u>	
<u>J. Evidence of storm sewer issues</u>	<u>Must be filmed</u>

***If camera inspection reveals the homes sanitary/storm main line(s) has issues, you will be required to repair/or replace the homes main sanitary sewer lateral or storm lines. All homeowners are responsible for the homes main line, from the home to the connection of the public main sewer lines. This will be determined by the Village of Northfield Building and Zoning Inspector and/or Village Engineer.**

STORM & SANITARY LINES MUST BE FILMED. STORM SYSTEM LOOKS TO HAVE ISSUES AND MUST BE PROPERLY CONNECTED TO STORM MAIN AT ROADSIDE.

13. **FOUNDATION ABOVE GRADE:** 1422.03 Commercial; 1490.03 Residential

A. Stoops deteriorated/not level	Replace/repair/re level
B. Steps/stoops not secure	Anchor properly
C. Deteriorated brick, stone, and or concrete	Replace/repair
<u>D. Unsafe, missing, unsecured railing</u>	<u>Replace/repair</u>
E. Not weather tight	Fill/seal

14. WINDOW WELLS: 1422.05 Commercial; 1490.05 Residential

<u>A. Drains blocked</u>	<u>Clean and maintain</u>
B. Deteriorated masonry	Replace/repair
<u>C. General condition</u>	<u>Repair</u>

15. CHIMNEY: 1422.05 Commercial; 1490.05 Residential

<u>A. Mortar joints not weather tight</u>	<u>Rake and properly repoint</u>
B. Deteriorated protective cap	Repair/replace
C. Broken, flaking spalled brick	Replace where deteriorated
D. Draft deflector broken/missing	Replace/repair

16. SCREENING: 1422.05 Commercial; 1490.05 Residential

A. Deteriorated torn fabric	Replace fabric
<u>B. Loose fabric or frame</u>	<u>Repair</u>
C. Portions Missing	Replace

17. PORCHES/DECKS: 1422.05 Commercial; 1490.05 Residential

<u>A. Loose missing floorboards</u>	<u>Replace/repair</u>
B. Loose missing ceiling boards	Replace/repair
C. Deteriorated/loose/missing railings	Replace/repair
<u>D. Deteriorated floor covering</u>	<u>Replace/repair</u>
E. Deteriorated support columns	Replace/repair
F. Deteriorated framing members	Replace/repair
<u>G. Dirty/unprotected</u>	<u>Wash/protect</u>

DECK NEEDS RESTORED.

18. CANOPIES/PATIO ENCLOSURES: 1422.05 Commercial; 1490.05 Residential

A. Loose attachment to structure	Anchor properly
B. Loose missing flashing	Replace/repair
C. Deteriorated portions	Replace/repair
D. Inadequate structural support	Install proper support

NO VIOLATIONS

19. DETACHED STRUCTURES:

20. OVERALL PROPERTY CONDITION AND ADDITIONAL COMMENTS:

THIS HOUSE HAS ISSUES. BUILDING INSPECTOR JASON WALTERS WOULD LIKE TO KNOW WHO PUT THE PILE OF CAT FECES THAT WAS DUMPED ON THE DRIVEWAY AT THE WEST CORNER. LOOKS TO HAVE WATER PROBLEMS IN BASEMENT.

THIS PROPERTY WILL REQUIRES A MEETING WITH ANY POTENTIAL BUYERS AND THE BUILDING/ZONING SUPERINTENDENT, JASON WALTERS.

Repairs may be made by the buyer or the seller. All repairs shall be made within 60 days of the date of inspection unless other arrangements have been approved by the Building Department.

If the BUYER is to assume the responsibility of the repairs, a Letter of Commitment stating that they will assume that responsibility is required.

The BUYER is responsible for obtaining a Certificate of Occupancy from the Building Department.

Date of Inspection: 8/514 Date of Approval: NOT APPROVED

H. Jason Walters, Harold J. Walters, Building Inspector